

**OPTIMIZATION OF LOAD IN POWER NETWORKS: LINEAR AND NONLINEAR PROGRAMMING METHODS****Akhmedova Nargiza**

Navoi University of Innovations

2nd year student of electrical engineering

Scientific supervisor: p.f.f.d., dots. **N.R. Saidova**

Associate Professor of Navoi University of Innovations

**Abstract:** The optimization of electrical load distribution within power networks is a fundamental problem in modern energy systems. Efficient load allocation ensures reduced energy loss, stability of power systems, and economical operation of generation units. This paper explores the application of linear and nonlinear programming methods to optimize load flow and minimize operational costs in electrical grids. The study compares mathematical models, discusses algorithmic approaches such as the simplex method and gradient-based optimization, and highlights their advantages and limitations in real-world power network operations. The integration of optimization algorithms with modern digital technologies, including smart grids and artificial intelligence, is also analyzed as a key step toward sustainable energy management.

**Keywords:** power system optimization, load distribution, linear programming, nonlinear programming, energy efficiency, simplex method, Lagrange multiplier, smart grids.

Power networks are complex systems that require continuous optimization to maintain stability and minimize losses. The growing demand for electrical energy, integration of renewable resources, and dynamic consumption patterns have made the optimization of load distribution a critical challenge for power system engineers.

Optimization methods, particularly linear programming (LP) and nonlinear programming (NLP), provide mathematical frameworks to model and solve such problems efficiently. The goal is to determine the optimal power flow (OPF) — i.e., how power should be generated, transmitted, and consumed — while satisfying physical and operational constraints. Historically, power system optimization was primarily based on linear models due to their simplicity and computational feasibility. However, as modern networks incorporate nonlinear components and stochastic behavior (such as varying renewable generation), nonlinear programming has become increasingly relevant. This paper investigates both methods, highlighting how they contribute to minimizing power loss, improving voltage profiles, and ensuring cost-effective operation of power systems. Load optimization in power networks refers to the process of allocating electrical load among various generation and transmission units in a way that meets demand while minimizing operational costs and losses. The optimization problem can be expressed as:

$$\text{\text{Minimize: }} C = \sum_{i=1}^n f_i(P_i)$$

$$\text{\text{Subject to: }} \sum_{i=1}^n P_i = P_D + P_L$$

$$P_i^{\min} \leq P_i \leq P_i^{\max}$$

where  $P$  is the total cost,  $f_i$  represents the cost function of each generating unit,  $D$  is the total demand, and  $L$  is the transmission loss.

The main objective is to achieve economic dispatch — the allocation of generation levels that minimizes cost without violating system constraints. Linear and nonlinear models differ in how the cost function and constraints are expressed. In linear models, both objective and constraints are linear functions of the decision variables. In nonlinear models, the relationships are nonlinear, often reflecting realistic system characteristics like transmission losses or generator efficiency curves.

Linear programming (LP) is one of the most fundamental optimization tools used in engineering. It deals with problems where both the objective function and constraints are linear.

In power networks, LP is applied to problems such as economic load dispatch and power flow optimization. The general form is:

$$\text{Minimize: } Z = c_1x_1 + c_2x_2 + \dots + c_nx_n$$

$$\text{Subject to: } A \mathbf{x} \leq \mathbf{b}, \quad x_i \geq 0$$

where  $x_i$  represents generation levels or load variables,  $c_i$  are cost coefficients, and  $A$  and  $b$  define system constraints.

The Simplex Method, proposed by Dantzig, is widely used to solve LP problems. In load optimization, it efficiently determines the combination of generation units that minimizes cost while meeting demand. Advantages of LP methods include:

- High computational efficiency;
- Well-established mathematical foundation;
- Guaranteed global optimum for convex problems.

However, linear models often fail to capture nonlinear phenomena such as transmission losses, generator heat rates, or reactive power variations. Therefore, nonlinear programming is required for more accurate representation.

Nonlinear programming (NLP) is used when either the objective function or constraints are nonlinear. In electrical power systems, generator cost curves are often quadratic, and power losses vary nonlinearly with load and voltage. A typical NLP formulation for economic dispatch is:

$$\text{Minimize: } C = \sum_{i=1}^n (a_i P_i^2 + b_i P_i + c_i)$$

$$\text{Subject to: } \sum_{i=1}^n P_i = P_D + P_L(P_i)$$

Here,  $a_i$ ,  $b_i$ , and  $c_i$  are the cost coefficients for each generating unit, and  $P_L$  denotes power losses, which depend on load flow. Solving NLP problems typically involves gradient-based methods, Lagrange multipliers, or Karush–Kuhn–Tucker (KKT) conditions. These methods iteratively adjust the generation levels to minimize the objective while satisfying nonlinear constraints. However, NLP algorithms may converge to local minima instead of a global optimum, and they

often require greater computational resources. Comparison Between Linear and Nonlinear Methods:

Aspect Linear Programming (LP) Nonlinear Programming (NLP)

Objective Function Linear Nonlinear (quadratic, exponential, etc.)

Constraints Linear May include nonlinear equalities/inequalities

Accuracy Moderate High (realistic system modeling)

Computational Time Low High

Convergence Global optimum guaranteed May reach local optimum

Practical Use Simplified systems Realistic, large-scale networks

In practice, a hybrid approach is often used: LP provides an initial feasible solution, which is then refined using NLP for more accurate optimization. Moreover, metaheuristic algorithms such as Genetic Algorithms (GA) or Particle Swarm Optimization (PSO) can complement these methods to overcome non-convexity challenges. The integration of optimization techniques has become crucial for smart grid management, renewable energy scheduling, and demand-side management. Linear and nonlinear programming models are embedded into Energy Management Systems (EMS) to control generation dispatch and optimize transmission flows in real-time. In smart grids, sensors and AI-based systems collect and analyze data to adjust loads dynamically using optimization models. For instance: Linear models are used for short-term generation scheduling and Nonlinear models are applied for long-term optimization and renewable integration. Furthermore, modern systems use Mixed-Integer Nonlinear Programming (MINLP) to handle discrete control variables, such as switch statuses and unit commitment decisions. This combination enhances system reliability and operational flexibility.

Although optimization techniques have greatly improved system efficiency, several challenges remain:

- Modeling the uncertainty of renewable sources (solar, wind);
- Handling large-scale systems with nonlinear constraints;
- Balancing real-time control with computational limits.

Emerging methods such as machine learning-assisted optimization, stochastic programming, and multi-objective optimization are expected to revolutionize load management. These approaches allow systems to self-adapt and maintain stability under fluctuating conditions.

Optimizing load in power networks is essential for achieving sustainable and reliable energy systems. Linear programming offers simplicity and computational speed, while nonlinear programming ensures accuracy and realism in modeling. The integration of both approaches, combined with artificial intelligence and smart grid technologies, represents the future of power system optimization. Through the synergy of mathematical modeling and digital control, modern power systems can achieve minimal losses, stable operation, and economically efficient energy distribution.

**References:**

1. Wood, A. J., & Wollenberg, B. F. Power Generation, Operation, and Control. John Wiley & Sons, 2012.
2. Dantzig, G. B. Linear Programming and Extensions. Princeton University Press, 1963.
3. Saadat, H. Power System Analysis. McGraw-Hill, 2010.
4. Grainger, J. J., & Stevenson, W. D. Power System Analysis. McGraw-Hill, 1994.
5. Momoh, J. A., Electric Power System Applications of Optimization. CRC Press, 2017.
6. Deb, K. Optimization for Engineering Design: Algorithms and Examples. PHI Learning, 2019.
7. Zhang, P. et al. "Smart Grid Load Optimization Using Hybrid NLP Methods." IEEE Transactions on Power Systems, 2021.